

Bahamas Power and Light Company Limited  
Hurricane Matthew Restoration  
Command Center Operations  
Open Job Ticks: October 28, 2016

			Customers Impacted	Fri	Sat	Sun	
1	Palmetto Ave	Broken lv pole - off Blue Hill Rd	1	x			
2	Sun Oil		1	x	x		
3	Tropical Gardens	Tropical Gadens & West Bay St - LV pole and service	1	x			
4	Woodland Way	Village Rd - Broken lv pole	1		x		
5	Yamacraw	Yamacraw Beach Estates	25	x			A number of low voltage cables in this area were affected due to flooding as a result of the storm surge/rain. Water damaged low voltage service pillars and entered in to the underground cables. Teams are working to either replace the affected cables or to bypass them using temporary overhead lines until they can be replaced
6	Blue Hill Rd Clinic	Abnormal voltage	1				
7	Mt Pleasant	NPDco Water Supply	0	x			In progress
8	St Michael Rd	leaning pole	0		x		
9	North Farrington Rd	Hill York, Farrington Rd pole & lines down	1	x			
10	Marshall Rd	Customers Impacted Due To Flooding - Area On	10				Awaiting indiviual customers' Electrical Repairs/Remediation and the issuance of an Electrical Inspection Clearance Certificate from the Ministry of Works. Customers will be reconnected as they provide the certificates
11	Lumumba Lane / Hanna Rd	Customers Impacted Due To Flooding - Area On	3				Awaiting indiviual customers' Electrical Repairs/Remediation and the issuance of an Electrical Inspection Clearance Certificate from the Ministry of Works. Customers will be reconnected as they provide the certificates
12	Yamacraw Shores / St And Bch Est	Customers Impacted Due To Flooding - Area On	1				Awaiting indiviual customers' Electrical Repairs/Remediation and the issuance of an Electrical Inspection Clearance Certificate from the Ministry of Works. Customers will be reconnected as they provide the certificates
13	Sappodilla Blvd	Sappodilla Blvd east off 2nd left (Bay Geranium), left at T, straight across to dead end lv pole down	1	x	x		Need to confirm
14	Pineyard Rd	4th pole from Fox Hill Rd - pole broken - supplies on			x		
15	South Beach	Oxford Dr. behind bldg #32. Broken lv pole - tractor needed to clear path	1		x	x	Tractor needed
17	Francis Ave. off Ambrister St.	Retention HV lines	10	x			
18	Millers Heights - East Ave.	Burnt HV Tx Pole change	10	x			

			Customers Impacted	Fri	Sat	Sun	
19	East Bay st. East of Williams Lane	LV lines down	1		x		
20	BHPS near Water Plant	Burnt HV Pole change	1		x		
21	McKinney Dr.	Burnt Air-break switch pole	0		x	x	
22	Sunset Dr. Sunset Park	HV line to tie off near house #6		x			
23	Carmichael Rd. near Lazaretto Rd.	LV lines down	4	x			
24	Rock Plant Rd.	HV poles down	1			x	
25	Bricknock Sub.	Broken HV Tx. pole	0	x	x		
26	Adelaide Rd.	Broken HV pole			x		
27	Rubis Bahamas - Clifton Pier dock terminal	No supply	1	x	x		
28	Firetrail West	Faulty 25Kva Tx.	1	x	x		
29	Bahamas Air Hanger	LV cable to be erected	1	x			
30	Romer St. Fox Hill						
31	Bishop St. Nassau Village	LV lines		x			
32	Tuckaway Road	LV cable fault - one phase out	5		x		
33	Sandford Drive - US Ambassador Residence	Erect HV cable	1	x			
34	Trinidad Way - Elizabeth Estates	Broken HV pole			x	x	
35	Seagull Gardens	Broken HV Tx. Bank pole			x	x	
36	Government House Grounds	LV lines down			x		
37	Sealink Dr. - Hoise #64, Dirt Rd.	LV pole down	2	x	x		
38	Shirley Park Ave	LV pole down			x		
39	Hanna Road West of Marigold Farm Rd.	Burnt/broken HV pole	80	x			Tx bank pole to be grounded off.
40	Klonaris Close near Hammerin Hank	Broken HV pole	5		x		Need to confirm - Pole pulled down by truck
			<b>170</b>				